

We use some essential cookies to make this service work.

We'd also like to use analytics cookies so we can understand how you use the service and make improvements.

Accept analytics cookiesReject analytics cookiesView cookies

# Energy performance certificate (EPC)

## Certificate contents

- Rules on letting this property
- Energy rating and score
- Breakdown of property's energy performance
- Environmental impact of this property
- Changes you could make
- Estimated energy use and potential savings
- Contacting the assessor and accreditation scheme
- Other certificates for this property

## Share this certificate

- Email
- Copy link to clipboard
- Print

Flat 4 32 Weston Road GLOUCESTER GL1 5AU		Energy rating  C
Valid until 15 May 2033	Certificate number 2100-1157-1170-4004-9221	

Property type	Mid-floor flat
Total floor area	21 square metres

## Rules on letting this property

Properties can be let if they have an energy rating from A to E.

You can read [guidance for landlords on the regulations and exemptions](#).

## Energy rating and score

This property's current energy rating is C. It has the potential to be C.

[See how to improve this property's energy efficiency.](#)

Score	Energy rating	Current	Potential
92+	A		
81-91	B		
69-80	C	73 C	77 C
55-68	D		
39-54	E		
21-38	F		
1-20	G		

The graph shows this property's current and potential energy rating.

**Properties get a rating from A (best) to G (worst) and a score.** The better the rating and score, the lower your energy bills are likely to be.

For properties in England and Wales:

- the average energy rating is D
- the average energy score is 60

## Breakdown of property's energy performance

### Features in this property

Features get a rating from very good to very poor, based on how energy efficient they are. Ratings are not based on how well features work or their condition.

Assumed ratings are based on the property's age and type. They are used for features the assessor could not inspect.

Feature	Description	Rating
Wall	Solid brick, as built, no insulation (assumed)	Very poor
Window	Fully double glazed	Average
Main heating	Boiler and radiators, mains gas	Good
Main heating control	Programmer, room thermostat and TRVs	Good
Hot water	From main system	Good
Lighting	Low energy lighting in all fixed outlets	Very good
Roof	(another dwelling above)	N/A
Floor	(another dwelling below)	N/A
Secondary heating	None	N/A

### Primary energy use

The primary energy use for this property per year is 264 kilowatt hours per square metre (kWh/m2).

► [What is primary energy use?](#)

## Environmental impact of this property

This property's current environmental impact rating is C. It has the potential to be B.

Properties get a rating from A (best) to G (worst) on how much carbon dioxide (CO2) they produce each year. CO2 harms the environment.

An average household produces	6 tonnes of CO2
This property produces	1.0 tonnes of CO2
This property's potential production	0.7 tonnes of CO2

You could improve this property's CO2 emissions by making the suggested changes. This will help to protect the environment.

Environmental impact ratings are based on assumptions about average occupancy and energy use. They may not reflect how energy is consumed by the people living at the property.

## Changes you could make

► [Do I need to follow these steps in order?](#)

### Step 1: Internal or external wall insulation

Typical installation cost	£4,000 - £14,000
Typical yearly saving	£114
Potential rating after completing step 1	77 C

### Paying for energy improvements

You might be able to get a grant from the [Boiler Upgrade Scheme](#). This will help you buy a more efficient, low carbon heating system for this property.

## Estimated energy use and potential savings

Based on average energy costs when this EPC was created:

Estimated yearly energy cost for this property	£576
Potential saving if you complete every step in order	£114

The estimated cost shows how much the average household would spend in this property for heating, lighting and hot water. It is not based on how energy is used by the people living at the property.

### Heating use in this property

Heating a property usually makes up the majority of energy costs.

#### Estimated energy used to heat this property

Type of heating	Estimated energy used
Space heating	2011 kWh per year
Water heating	1361 kWh per year

#### Potential energy savings by installing insulation

Type of insulation	Amount of energy saved
Solid wall insulation	1067 kWh per year

### Saving energy in this property

[Find ways to save energy in your home.](#)

## Contacting the assessor and accreditation scheme

This EPC was created by a qualified energy assessor.

If you are unhappy about your property's energy assessment or certificate, you can complain to the assessor directly.

If you are still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation schemes are appointed by the government to ensure that assessors are qualified to carry out EPC assessments.

### Assessor contact details

Assessor's name	David Hughes
Telephone	01249466999
Email	<a href="mailto:dave@hughesandhughes.agency">dave@hughesandhughes.agency</a>

### Accreditation scheme contact details

Accreditation scheme	Quidos Limited
Assessor ID	QUID209307
Telephone	01225 667 570
Email	<a href="mailto:info@quidos.co.uk">info@quidos.co.uk</a>

### Assessment details

Assessor's declaration	No related party
Date of assessment	21 March 2023
Date of certificate	16 May 2023
Type of assessment	► <a href="#">RdSAP</a>

## Other certificates for this property

If you are aware of previous certificates for this property and they are not listed here, please contact us at [dluhc.digital-services@levellingup.gov.uk](mailto:dluhc.digital-services@levellingup.gov.uk) or call our helpdesk on 020 3829 0748 (Monday to Friday, 9am to 5pm).

Certificate number	<a href="#">0062-2820-6370-2390-2025</a>
Valid until	10 March 2030
Certificate number	<a href="#">9062-2822-6300-9301-8075</a>
Valid until	18 December 2029
Certificate number	<a href="#">8601-6325-6300-2202-0026</a>
Expired on	21 May 2019

